LIFTINSTITUUT

EC TYPE-EXAMINATION CERTIFICATE

Acting under the Warenwetbesluit liften issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Besluit no. A&G/W&P/03 56126 dated October 15th, 2003

Certificate nr.	: NL 05-400-1002-068-01	Object nr.: 1002-068-01
Description of the product	: Door locking device with hook for horizontal power operated sliding doors. Both central and side opening	
Trademark, type	: Adoor, ALD 100 Door locking device	
Name and address of the manufacturer	: Adoor, Ilgenler Insaat Makina San. Ve TIC. LTD. ŞTI. Sivas yolu 7. Km. No:381 Kayseri, Turkey	
Name and address of the certificate holder	: Adoor, Ilgenler Insaat Makina San. Ve TIC. LTD. ŞTI. Sivas yolu 7. Km. No:381 Kayseri, Turkey	
Certificate issued on the basis of the following requirements	: Lifts Directive 95/16/EC, EN 81-1/2	
Test laboratory	: Adoor, Ilgenler Insaat Makina San. Ve TIC. LTD. ŞTI. Sivas yolu 7. Km. No:381 Kayseri, Turkey Liftinstituut, Amsterdam	
Date and number of the laboratory report	: Report belonging to EC-type examination nr.: NL 05-400-1002-068-01	
Date of EC type-examination	: May 2005	
Annexes with this certificate	Report belonging to the EC type-examination certificate nr.: NL 04-400-1002-068-01	
Additional remarks	: Max. rated voltage 230 VAC Max. rated current 0,5A Max. door height 2300 mm Door width 700 - 1300 mm	
Conclusion	: The safety component meets the requirements of the Lifts Directive 95/16/EG taking into account any additional remarks mentioned above	

Issued in Amsterdam
Date of issue : May 24, 2005

LIFTINSTITUUT B.V.
managing director

LIFTINSTITUUT B.V., BUIKSLOTERMEERPLEIN 381, 1025 XE – P.O. Box 36027, 1020 MA AMSTERDAM